



May 10, 2019

Mayor and Council  
Town of Kenaston  
Box 129  
KENASTON, SK  
S0KG 2N0

Dear Mayor and Council:

This letter is to advise you that a **Precautionary Drinking Water Advisory (PDWA) is being issued for the Town of Kenaston's drinking water distribution system affecting all users and is effective: Friday, May 10, 2019 until further notice.**

Water Security Agency protocol is to place systems under a PDWA if they anticipate an upset condition or experience a depressurization until such a time as the drinking water system is proven safe for human consumptive use. This Precautionary Drinking Water Advisory remains in effect until the safety of the Kenaston drinking water distribution system can be ensured at all times. Therefore, you are required to notify all affected users of the drinking water distribution system of the conditions in the attached Precautionary Drinking Water Advisory.

This advisory can be rescinded following:

- 1) The drinking water system is re-pressurized and the system is flushed according to applicable standards; and
- 2) The receipt of two consecutive sets of three (3) bacteriological samples collected at least one day apart (and marked as 'other') that are negative for bacteriological growth in the final treated potable water being supplied to the distribution system (6 total samples minimum).

Thank you for your cooperation in this regard. For further information please do not hesitate to contact the undersigned at 946-3233.

Sincerely,

A handwritten signature in black ink, appearing to read "Gary Papic", is written over a light blue circular watermark.

Gary Papic, A.Sc.T.  
Senior Environmental Project Officer  
Water Security Agency

cc. Jim Webster, Heartland Health Region  
Barry Wright Manager, North Region  
Environmental and Municipal Management Services Division, Regina  
Patrick Boyle, Communications Manager